

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3266-0735:107 Page 1 of 1

CATEGORY: Door Operators

LISTEE: Besam Automated Entrance System, 84 Twin Rivers Dr., Hightstown, NJ 08520
Contact: Bruce Campbell (609) 443-5800

DESIGN: Model "Unislide" commercial and residential pedestrian door operator with automatic closer. Unit is intended for use to operate single or multiple automatic sliding doors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as door operator for use with single or *multiple sliding doors in exit locations where fire-rated doors are not required. Authority having jurisdiction should be consulted prior to installation.

*Corrected 06-13-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager